

WATER MANAGEMENT SECRETARIAT - MAHAWELI AUTHORITY OF SRI LANKA

Decisions arrived at the Weekly Operational Meeting held on **28-Nov-2008**

for week no. **10** from **1-Dec-2008**

Subject	Recommended Action	Remarks
(1) Power Releases		
Victoria	CEB requirement	-
Moussakele	CEB requirement	-
Castlereigh	CEB requirement	-
Bowatenna	700 cfs	14 hrs. @ 11 MW, 2 staggers
Polgolla	Bow req.	
Samanalawewa	CEB requirement	-
Gamini Dissanayake Reservoir (Kotmale)	Polg req.	
Randenigala	CEB requirement	-
Rantembe	66 cms	20 hrs. @ 25 MW
(2) Irrigation Diversions		
Minipe RB	balance	
Minipe LB	17 cms	
Minipe D/S	-	
Bowatenna to		
(a) Dambuluoya	800 cfs	-
(b) KH canal	200 cfs	
(i) Huruluwewa @ KH bifurcation	125 cfs	
(ii) Kandalama @ KH bifurcation	balance	
Elahera	700 cfs	-
Angamedilla	-	
System A	-	
Kaltota	1.5 cms	on request -2.0 cms
(3) Other important decisions in brief		
3.1 EIC(Mapakada) to maintain Minipe WL at FSL for Minipe LB to take 17 cms .		
3.2 EIC (Maduru oya) to half open Maduru oya link tunnel from Monday and Ulhitiya WL above 105.5 masl full open the tunnel.		
3.3 CEB to maintain Bowatenna WL @ 247 masl.		
28-Nov-08 Date		
Last updated 28-Nov-08		